



Føllenslev Vandværk

Årsrapport 2014



Mængder

Udpumpet vandmængde:	Total: 12,8 m ³	Måler 1: 20.143,3 m ³	Måler 2: 9.470,8 m ³
Indvundet vandmængde:	Total: 29.571,7 m ³	Måler 3: 29.571,7 m ³	

Forbrug

Elforbrug:	Total: 23.381,5 kWh	Udpumpet: 939.700,0 kWh
	Total: 1.827,81 kWh/m ³	Udpumpet: 73.459,40 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 30-08-14 00:06:06
Max. Flow:	20,00 m ³ /h	Tidspunkt: 18-09-14 05:25:28

Flow måler 2:

		02-09-14 00:00:00
Min. Flow:	0,00 m ³ /h	Tidspunkt:
Max. Flow:	9,02 m ³ /h	Tidspunkt: 01-10-14 14:22:13

Niveauer i boringer:

Boring 1 niveau:	Højest: 0,00 m	Lavest: -13,88 m	Sænkning: 13,88 m
Boring 2 niveau:	Højest: 0,00 m	Lavest: -6,91 m	Sænkning: 6,91 m
Boring 3 niveau:	Højest: 0,00 m	Lavest: -6,92 m	Sænkning: 6,92 m

Filter:

Filter 1:	Antal skyl: 52
Filter 2:	Antal skyl: 28

Drifttimer:

	Periode:	Total:
Boring 1:	518 Timer	527 Timer
Boring 2:	378 Timer	381 Timer
Boring 3:	325 Timer	326 Timer
Pumpe 1:	1473 Timer	1496 Timer
Pumpe 2:	1527 Timer	1535 Timer
Pumpe 3:	1051 Timer	1072 Timer
Pumpe 4:	1098 Timer	1106 Timer
Pumpe 5:	0 Timer	0 Timer