

DRIFTSRAPPORT

Månedssrapport December 2022

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	1821,82 m ³
Boring 1	923,54 m ³
Boring 2	898,28 m ³
TOTAL UDPUMPET	1794,12 m ³
Udpumpning	1794,12 m ³
TOTAL SKYLLEVAND	6,84 m ³
Skyllevand	6,84 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	1926 kWh
Delproces / udpumpning	778 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	6 skyl
Filter 4	6 skyl

DRIFTTIMER



BORINGER	
1	113 timer
2	110 timer
PUMPER	
1	380 timer
2	364 timer
FILTERMOTOR	
1	223 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport December 2022

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,67 m	-54,37 m	4,70 m	923,54 m ³
2	-49,54 m	-53,94 m	4,40 m	898,28 m ³

Fordeling for indvundet vand



Blue Control®
BC7000