

# DRIFTSRAPPORT

Årsrapport 2020

Føllenslev Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	40878,69 m <sup>3</sup>
Indvinding	40878,69 m <sup>3</sup>
Boring 2	14887,23 m <sup>3</sup>
Boring 3	17836,15 m <sup>3</sup>
TOTAL UDPUMPET	40660,51 m <sup>3</sup>
Lavtrykszone	23635,81 m <sup>3</sup>
Højtrykszone	17024,71 m <sup>3</sup>

## ELFORBRUG



ELFORBRUG	
Samlet proces	30258 kWh
Delproces / udpumpning	37710 kWh



## NATFORBRUG



## FILTRE

Filter 1	206 skyl
Filter 2	68 skyl

## DRIFTTIMER



BORINGER	
1	927 timer
2	1956 timer
PUMPER	
1	5069 timer
2	4882 timer
3	4269 timer
4	4220 timer
5	4215 timer
FILTERMOTOR	
1	39 timer



Blue Control®  
BC7000



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-5,00 m	-13,26 m	8,25 m	40878,69 m <sup>3</sup>
2	0,91 m	-11,00 m	11,91 m	14887,23 m <sup>3</sup>

