



Føllenslev Vandværk

Månedssrapport 10-2014



Mængder

Udpumpet vandmængde:	Total:	2.556,8 m ³	Måler 1:	1.730,4 m ³	Måler 2:	826,4 m ³
Indvundet vandmængde:	Total:	2.549,0 m ³	Måler 3:	2.549,0 m ³		

Forbrug

Elforbrug:	Total:	1.973,6 kWh	Udpumpet:	51.953,3 kWh
	Total:	0,77 kWh/m ³	Udpumpet:	20,32 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-10-14 00:00:18
Max. Flow:	13,09 m ³ /h	Tidspunkt: 01-10-14 16:52:48

Flow måler 2:

		01-10-14 00:00:00
Min. Flow:	0,00 m ³ /h	Tidspunkt:
Max. Flow:	9,02 m ³ /h	Tidspunkt: 01-10-14 14:22:13

Niveauer i boringer:

Boring 1 niveau:	Højest:	0,00 m	Lavest:	-13,87 m	Sænkning:	13,87 m
Boring 2 niveau:	Højest:	0,00 m	Lavest:	-6,91 m	Sænkning:	6,91 m
Boring 3 niveau:	Højest:	0,00 m	Lavest:	-6,86 m	Sænkning:	6,86 m

Filter:

Filter 1:	Antal skyl:	15
Filter 2:	Antal skyl:	7

Drifttimer:

	Periode:	Total:
Boring 1:	196 Timer	432 Timer
Boring 2:	93 Timer	180 Timer
Boring 3:	58 Timer	124 Timer
Pumpe 1:	390 Timer	812 Timer
Pumpe 2:	423 Timer	857 Timer
Pumpe 3:	241 Timer	555 Timer
Pumpe 4:	257 Timer	630 Timer
Pumpe 5:	247 Timer	354 Timer