

DRIFTSRAPPORT

Månedsrapport Juli 2019

Føllenslev Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	3112,74 m ³
Indvinding	3112,74 m ³
Boring 2	1250,13 m ³
Boring 3	1097,67 m ³
TOTAL UDPUMPET	3110,08 m ³
Udpumpning	1980,37 m ³
Udpumpning	1129,72 m ³

ELFORBRUG



ELFORBRUG	
Samlet proces	2264 kWh
Delproces / udpumpning	1497 kWh



NATFORBRUG



FILTRE

Filter 1	16 skyl
Filter 2	6 skyl

DRIFTTIMER



BORINGER	
1	122 timer
2	142 timer
3	124 timer
PUMPER	
1	416 timer
2	394 timer
3	316 timer
4	316 timer
5	327 timer
FILTERMOTOR	
1	3 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Juli 2019

Føllenslev Vandværk

2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-5,62 m	-13,35 m	7,73 m	3112,74 m ³
2	-6,13 m	-8,73 m	2,60 m	1250,13 m ³
3	-4,47 m	-6,87 m	2,40 m	1097,67 m ³



Blue Control®
BC7000