





Føllenslev Vandværk

Månedsrapport 10-2013



Mængder

Udpumpet vandmængde:	Total: 2465 m ³	Måler 1: 1716 m ³	Måler 2: 749 m ³
Indvundet vandmængde:	Total: 2448 m ³	Måler 3: 2448 m ³	

Forbrug

Elforbrug:	Total: 2136 kWh		
	Total: 0.87 kWh/m ³	Udpumpet:	0.61 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	0.00 m ³ /h	Tidspunkt: 01-10-13 00:06:56
Max. Flow:	10.97 m ³ /h	Tidspunkt: 14-10-13 18:31:20

Flow måler 2:

Min. Flow:	0.00 m ³ /h	Tidspunkt: 01-10-13 00:00:00
Max. Flow:	6.27 m ³ /h	Tidspunkt: 06-10-13 10:12:20

Niveauer i boreriger:

Boring 1 niveau:	Højest: -5.57 m	Lavest: -13.58 m	Sænkning: 8.01 m
Boring 2 niveau:	Højest: -4.10 m	Lavest: -7.49 m	Sænkning: 3.39 m
Boring 3 niveau:	Højest: -3.89 m	Lavest: -6.84 m	Sænkning: 2.94 m

Filter:

Filter 1:	Antal skyl: 8
Filter 2:	Antal skyl: 4

Drifttimer:

	Periode:	Total:
Boring 1:	43 Timer	630 Timer
Boring 2:	128 Timer	1057 Timer
Boring 3:	125 Timer	944 Timer
Pumpe 1:	575 Timer	4306 Timer
Pumpe 2:	580 Timer	4432 Timer
Pumpe 3:	442 Timer	4113 Timer
Pumpe 4:	430 Timer	4006 Timer