

DRIFTSRAPPORT

Månedssrapport December 2019

Føllenslev Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	5758,67 m ³
Indvinding	5758,67 m ³
Boring 2	2073,20 m ³
Boring 3	2077,40 m ³
TOTAL UDPUMPET	5666,84 m ³
Udpumpning	1824,84 m ³
Udpumpning	3842,00 m ³

ELFORBRUG



ELFORBRUG	
Samlet proces	4204 kWh
Delproces / udpumpning	2938 kWh



NATFORBRUG



FILTRE

Filter 1	31 skyl
Filter 2	9 skyl

DRIFTTIMER



BORINGER	
1	249 timer
2	245 timer
3	254 timer
PUMPER	
1	420 timer
2	395 timer
3	660 timer
4	641 timer
5	642 timer
FILTERMOTOR	
1	6 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport December 2019

Føllenslev Vandværk

2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-5,23 m	-12,60 m	7,38 m	5758,67 m ³
2	-5,33 m	-81,42 m	76,09 m	2073,20 m ³
3	-3,93 m	-8,30 m	4,37 m	2077,40 m ³



Blue Control®
BC7000