





# Føllenslev Vandværk

## Årsrapport 2013



## Mængder

Udpumpet vandmængde:	Total: 27224 m <sup>3</sup>	Måler 1: 19239 m <sup>3</sup>	Måler 2: 7985 m <sup>3</sup>
Indvundet vandmængde:	Total: 26983 m <sup>3</sup>	Måler 3: 26983 m <sup>3</sup>	

## Forbrug

Elforbrug:	Total: 18375 kWh		
	Total: 0.67 kWh/m <sup>3</sup>	Udpumpet:	0.51 kWh/m <sup>3</sup>

## Flow

### Flow måler 1:

Min. Flow:	0.00 m <sup>3</sup> /h	Tidspunkt: 17-01-13 09:53:02
Max. Flow:	20.00 m <sup>3</sup> /h	Tidspunkt: 31-01-13 10:44:59

### Flow måler 2:

Min. Flow:	0.00 m <sup>3</sup> /h	Tidspunkt: 17-01-13 09:53:02
Max. Flow:	14.50 m <sup>3</sup> /h	Tidspunkt: 15-11-13 14:03:21

## Niveauer i boreriger:

Boring 1 niveau:	Højest: 26.57 m	Lavest: -5.31 m	Sænkning: 31.88 m
Boring 2 niveau:	Højest: 26.11 m	Lavest: -3.92 m	Sænkning: 30.03 m
Boring 3 niveau:	Højest: 26.30 m	Lavest: -3.63 m	Sænkning: 29.93 m

## Filter:

Filter 1:	Antal skyl:	95
Filter 2:	Antal skyl:	60

## Drifttimer:

	Periode:	Total:
Boring 1:	716 Timer	716 Timer
Boring 2:	1337 Timer	1337 Timer
Boring 3:	1168 Timer	1168 Timer
Pumpe 1:	5111 Timer	5111 Timer
Pumpe 2:	5286 Timer	5286 Timer
Pumpe 3:	4952 Timer	4952 Timer
Pumpe 4:	4842 Timer	4842 Timer