



Føllenslev Vandværk

Månedssrapport 12-2014



Mængder

Udpumpet vandmængde:	Total:	2.039,1 m ³	Måler 1:	1.313,4 m ³	Måler 2:	725,6 m ³
Indvundet vandmængde:	Total:	2.045,1 m ³	Måler 3:	2.045,1 m ³		

Forbrug

Elforbrug:	Total:	1.640,5 kWh	Udpumpet:	1.094,8 kWh
	Total:	0,80 kWh/m ³	Udpumpet:	0,54 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-12-14 00:00:13
Max. Flow:	12,22 m ³ /h	Tidspunkt: 14-12-14 09:13:49

Flow måler 2:

		01-12-14 00:00:27
Min. Flow:	0,00 m ³ /h	Tidspunkt:
Max. Flow:	7,65 m ³ /h	Tidspunkt: 31-12-14 10:25:44

Niveauer i boringer:

Boring 1 niveau:	Højest:	-5,38 m	Lavest:	-13,62 m	Sænkning:	8,24 m
Boring 2 niveau:	Højest:	-4,90 m	Lavest:	-6,67 m	Sænkning:	1,77 m
Boring 3 niveau:	Højest:	-4,13 m	Lavest:	-6,65 m	Sænkning:	2,52 m

Filter:

Filter 1:	Antal skyl:	10
Filter 2:	Antal skyl:	5

Drifttimer:

	Periode:	Total:
Boring 1:	44 Timer	527 Timer
Boring 2:	98 Timer	381 Timer
Boring 3:	99 Timer	326 Timer
Pumpe 1:	336 Timer	1496 Timer
Pumpe 2:	332 Timer	1535 Timer
Pumpe 3:	277 Timer	1072 Timer
Pumpe 4:	247 Timer	1106 Timer
Pumpe 5:	253 Timer	841 Timer