





Føllenslev Vandværk

Månedsrapport 03-2014



Mængder

Udpumpet vandmængde:	Total: 2590 m ³	Måler 1: 1807 m ³	Måler 2: 783 m ³
Indvundet vandmængde:	Total: 2575 m ³	Måler 3: 2575 m ³	

Forbrug

Elforbrug:	Total: 2047 kWh		
	Total: 0.79 kWh/m ³	Udpumpet:	0.54 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	0.00 m ³ /h	Tidspunkt: 01-03-14 00:21:36
Max. Flow:	11.73 m ³ /h	Tidspunkt: 08-03-14 09:33:53

Flow måler 2:

Min. Flow:	0.00 m ³ /h	Tidspunkt: 01-03-14 00:03:48
Max. Flow:	5.96 m ³ /h	Tidspunkt: 23-03-14 11:22:36

Niveauer i boreriger:

Boring 1 niveau:	Højest: -5.00 m	Lavest: -12.94 m	Sænkning: 7.94 m
Boring 2 niveau:	Højest: -3.30 m	Lavest: -6.87 m	Sænkning: 3.57 m
Boring 3 niveau:	Højest: -3.09 m	Lavest: -6.04 m	Sænkning: 2.96 m

Filter:

Filter 1:	Antal skyl: 8
Filter 2:	Antal skyl: 4

Drifttimer:

	Periode:	Total:
Boring 1:	50 Timer	862 Timer
Boring 2:	131 Timer	1728 Timer
Boring 3:	131 Timer	1508 Timer
Pumpe 1:	407 Timer	6307 Timer
Pumpe 2:	454 Timer	6566 Timer
Pumpe 3:	431 Timer	6217 Timer
Pumpe 4:	439 Timer	6099 Timer