

# DRIFTSRAPPORT

Månedssrapport November 2019

Føllenslev Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	3296,53 m <sup>3</sup>
Indvinding	3296,53 m <sup>3</sup>
Boring 2	1297,83 m <sup>3</sup>
Boring 3	1148,37 m <sup>3</sup>
TOTAL UDPUMPET	3273,03 m <sup>3</sup>
Udpumpning	1717,83 m <sup>3</sup>
Udpumpning	1555,20 m <sup>3</sup>

## ELFORBRUG



ELFORBRUG	
Samlet proces	2462 kWh
Delproces / udpumpning	1703 kWh



## NATFORBRUG



## FILTRE

Filter 1	18 skyl
Filter 2	5 skyl

## DRIFTTIMER



BORINGER	
1	130 timer
2	146 timer
3	134 timer
PUMPER	
1	385 timer
2	378 timer
3	398 timer
4	377 timer
5	353 timer
FILTERMOTOR	
1	3 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedsrapport November 2019

Føllenslev Vandværk

2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-5,26 m	-12,78 m	7,52 m	3296,53 m <sup>3</sup>
2	-4,33 m	-7,54 m	3,22 m	1297,83 m <sup>3</sup>
3	-4,13 m	-8,24 m	4,12 m	1148,37 m <sup>3</sup>



Blue Control®  
BC7000