





# Føllenslev Vandværk

## Månedssrapport 02-2014



## Mængder

Udpumpet vandmængde:	Total: 2260 m <sup>3</sup>	Måler 1: 1577 m <sup>3</sup>	Måler 2: 683 m <sup>3</sup>
Indvundet vandmængde:	Total: 2242 m <sup>3</sup>	Måler 3: 2242 m <sup>3</sup>	

## Forbrug

Elforbrug:	Total: 1803 kWh		
	Total: 0.80 kWh/m <sup>3</sup>	Udpumpet:	0.54 kWh/m <sup>3</sup>

## Flow

### Flow måler 1:

Min. Flow:	0.00 m <sup>3</sup> /h	Tidspunkt: 01-02-14 00:18:17
Max. Flow:	11.78 m <sup>3</sup> /h	Tidspunkt: 23-02-14 09:36:09

### Flow måler 2:

Min. Flow:	0.00 m <sup>3</sup> /h	Tidspunkt: 01-02-14 00:00:00
Max. Flow:	5.97 m <sup>3</sup> /h	Tidspunkt: 07-02-14 05:12:45

## Niveauer i boringer:

Boring 1 niveau:	Højest: -5.00 m	Lavest: -12.93 m	Sænkning: 7.93 m
Boring 2 niveau:	Højest: -3.31 m	Lavest: -6.79 m	Sænkning: 3.49 m
Boring 3 niveau:	Højest: -3.14 m	Lavest: -6.08 m	Sænkning: 2.94 m

## Filter:

Filter 1:	Antal skyl: 8
Filter 2:	Antal skyl: 4

## Drifttimer:

	Periode:	Total:
Boring 1:	52 Timer	812 Timer
Boring 2:	126 Timer	1597 Timer
Boring 3:	97 Timer	1377 Timer
Pumpe 1:	371 Timer	5900 Timer
Pumpe 2:	395 Timer	6112 Timer
Pumpe 3:	391 Timer	5786 Timer
Pumpe 4:	390 Timer	5660 Timer