





## Føllenslev Vandværk

### Månedssrapport 11-2013



### Mængder

Udpumpet vandmængde:	Total: 2468 m <sup>3</sup>	Måler 1: 1743 m <sup>3</sup>	Måler 2: 725 m <sup>3</sup>
Indvundet vandmængde:	Total: 2441 m <sup>3</sup>	Måler 3: 2441 m <sup>3</sup>	

### Forbrug

Elforbrug:	Total: 1942 kWh		
	Total: 0.79 kWh/m <sup>3</sup>	Udpumpet:	-3.55 kWh/m <sup>3</sup>

### Flow

#### Flow måler 1:

Min. Flow:	0.00 m <sup>3</sup> /h	Tidspunkt: 01-11-13 00:01:12
Max. Flow:	11.62 m <sup>3</sup> /h	Tidspunkt: 02-11-13 17:06:12

#### Flow måler 2:

Min. Flow:	0.00 m <sup>3</sup> /h	Tidspunkt: 01-11-13 00:03:41
Max. Flow:	14.50 m <sup>3</sup> /h	Tidspunkt: 15-11-13 14:03:21

### Niveauer i boreriger:

Boring 1 niveau:	Højest: 0.00 m	Lavest: -13.54 m	Sænkning: 13.54 m
Boring 2 niveau:	Højest: 0.00 m	Lavest: -7.39 m	Sænkning: 7.39 m
Boring 3 niveau:	Højest: 0.00 m	Lavest: -6.79 m	Sænkning: 6.79 m

### Filter:

Filter 1:	Antal skyl: 7
Filter 2:	Antal skyl: 4

### Drifttimer:

	Periode:	Total:
Boring 1:	53 Timer	683 Timer
Boring 2:	138 Timer	1195 Timer
Boring 3:	107 Timer	1051 Timer
Pumpe 1:	399 Timer	4705 Timer
Pumpe 2:	420 Timer	4852 Timer
Pumpe 3:	420 Timer	4533 Timer
Pumpe 4:	416 Timer	4422 Timer