





# Føllenslev Vandværk

## Månedssrapport 09-2014



## Mængder

Udpumpet vandmængde:	Total:	2.413,4 m <sup>3</sup>	Måler 1:	1.635,5 m <sup>3</sup>	Måler 2:	777,9 m <sup>3</sup>
Indvundet vandmængde:	Total:	2.465,0 m <sup>3</sup>	Måler 3:	2.465,0 m <sup>3</sup>		

## Forbrug

Elforbrug:	Total:	1.865,7 kWh	Udpumpet:	845.166,0 kWh
	Total:	0,77 kWh/m <sup>3</sup>	Udpumpet:	350,19 kWh/m <sup>3</sup>

## Flow

### Flow måler 1:

Min. Flow:	0,00 m <sup>3</sup> /h	Tidspunkt: 01-09-14 00:32:12
Max. Flow:	20,00 m <sup>3</sup> /h	Tidspunkt: 18-09-14 05:25:28

### Flow måler 2:

		01-09-14 00:00:00
Min. Flow:	0,00 m <sup>3</sup> /h	Tidspunkt:
Max. Flow:	7,67 m <sup>3</sup> /h	Tidspunkt: 17-09-14 11:28:10

## Niveauer i boringer:

Boring 1 niveau:	Højest:	0,00 m	Lavest:	-13,88 m	Sænkning:	13,88 m
Boring 2 niveau:	Højest:	0,00 m	Lavest:	-6,89 m	Sænkning:	6,89 m
Boring 3 niveau:	Højest:	0,00 m	Lavest:	-6,92 m	Sænkning:	6,92 m

## Filter:

Filter 1:	Antal skyl:	15
Filter 2:	Antal skyl:	8

## Drifttimer:

	Periode:	Total:
Boring 1:	209 Timer	236 Timer
Boring 2:	77 Timer	87 Timer
Boring 3:	57 Timer	66 Timer
Pumpe 1:	360 Timer	422 Timer
Pumpe 2:	384 Timer	434 Timer
Pumpe 3:	256 Timer	314 Timer
Pumpe 4:	328 Timer	373 Timer
Pumpe 5:	107 Timer	107 Timer