

DRIFTSRAPPORT

Årsrapport 2019

Føllenslev Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	39423,86 m ³
Indvinding	39423,86 m ³
Boring 2	10067,85 m ³
Boring 3	9491,02 m ³
TOTAL UDPUMPET	39289,45 m ³
Udpumpning	23264,10 m ³
Udpumpning	16025,35 m ³

ELFORBRUG



ELFORBRUG	
Samlet proces	30157 kWh
Delproces / udpumpning	20099 kWh



NATFORBRUG



FILTRE

Filter 1	230 skyl
Filter 2	68 skyl

DRIFTTIMER



BORINGER	
1	1602 timer
2	1693 timer
3	1641 timer
PUMPER	
1	5635 timer
2	5489 timer
3	4184 timer
4	4016 timer
5	4069 timer
FILTERMOTOR	
1	43 timer



Blue Control®
BC7000



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-5,20 m	-13,53 m	8,32 m	39423,86 m ³
2	-1,00 m	-81,42 m	80,42 m	10067,85 m ³
3	-3,93 m	-8,30 m	4,37 m	9491,02 m ³

