

DRIFTSRAPPORT

Månedsrapport Oktober 2019

Føllenslev Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2649,33 m ³
Indvinding	2649,33 m ³
Boring 2	1037,60 m ³
Boring 3	958,25 m ³
TOTAL UDPUMPET	2643,16 m ³
Udpumpning	1690,51 m ³
Udpumpning	952,64 m ³

ELFORBRUG



ELFORBRUG	
Samlet proces	1976 kWh
Delproces / udpumpning	1332 kWh



NATFORBRUG



FILTRE

Filter 1	15 skyl
Filter 2	5 skyl

DRIFTTIMER



BORINGER	
1	104 timer
2	117 timer
3	109 timer

PUMPER	
1	380 timer
2	378 timer
3	303 timer
4	293 timer
5	295 timer

FILTERMOTOR	
1	3 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Oktober 2019

Føllenslev Vandværk

2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-5,88 m	-13,35 m	7,47 m	2649,33 m ³
2	-6,36 m	-8,59 m	2,23 m	1037,60 m ³
3	-4,68 m	-6,77 m	2,09 m	958,25 m ³



Blue Control®
BC7000