

DRIFTSRAPPORT

Månedsrapport September 2019

Føllenslev Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2731,52 m ³
Indvinding	2731,52 m ³
Boring 2	1099,11 m ³
Boring 3	973,65 m ³
TOTAL UDPUMPET	2718,14 m ³
Udpumpning	1700,34 m ³
Udpumpning	1017,80 m ³

ELFORBRUG



ELFORBRUG	
Samlet proces	2042 kWh
Delproces / udpumpning	1381 kWh



NATFORBRUG



FILTRE

Filter 1	16 skyl
Filter 2	4 skyl

DRIFTTIMER



BORINGER	
1	105 timer
2	123 timer
3	111 timer

PUMPER	
1	391 timer
2	396 timer
3	307 timer
4	293 timer
5	320 timer

FILTERMOTOR	
1	3 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport September 2019

Føllenslev Vandværk

2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-5,45 m	-13,25 m	7,80 m	2731,52 m ³
2	-1,00 m	-8,54 m	7,54 m	1099,11 m ³
3	-4,30 m	-6,72 m	2,42 m	973,65 m ³



Blue Control®
BC7000